



DECLARATION OF CONFORMITY

According to the Norms:
EN10204-2.1 & UNI EN ISO / IEC 17050-1

The undersigned **IVR S.p.A.**
Producer of Hydrothermal Systems,
based in Boca (NO) Via Brughiera III no.1, Località Piano Rosa (Italy)

DECLARES

Under its sole responsibility that the product

Full bore ball valve – threaded ends F/F
954 – 954/A – 954/LD – 954 PLUS series

Are built in accordance with the technical requirements and with the procedures established by the Company Quality Management System compliant with the UNI EN ISO 9001:2015 standard. The full bore ball valve are designed and certified according to EN 13828:2004. Threaded ends in accordance to EN ISO 228-1:2003

Field of application:

- Suitable for use in the hydraulic, sanitary and compressed air industries
- Maximum working pressure: $\frac{1}{4}'' - \frac{3}{4}'' = 50 \text{ bar}$ / $1'' - 1\frac{1}{4}'' = 40 \text{ bar}$ / $1\frac{1}{2}'' - 2'' = 32 \text{ bar}$ / $2\frac{1}{2}'' - 4'' = 16 \text{ bar}$
- Operating temperature: $- 20^{\circ}\text{C}$ / $+ 150^{\circ}\text{C}$
- Use with antifreeze products (Glycole): maximum percentage = 50%

Notified body:

- ACS Attestation de Conformite Sanitaire
Registration number: 12 ACCLY 611
- WRAS
Registration number: 1609318

Notified body:

- TECHNICKÝ SKÚŠOBNÝ ÚSTAV PIEŠŤANY, Š.P.
Registration number: SK03 – ZSV – 0295
- NARODOWY INSTYTUT ZDROWIA
PUBLICZNEGO - PAŃSTWOWY ZAKŁAD HIGIENY
Registration number: BK/W/0020/01/2019

October 19th, 2020

IVR S.p.A.

Legal Representative
Piero Giacomini

Sede Amministrativa: Via Brughiera III n.1 Località Piano Rosa – 28010 BOCA (NO)

Sede Legale: Via Francesco Melzi d'Eril n.7 – 20154 MILANO (MI)

Codice Fiscale e Partita IVA 06829530960 – Registro Imprese di Milano n. 06829530960 – R.E.A. Milano n. 1918135
Tel. 0322 888811 – Fax 0322 888892-93 website www.ivrvalvole.it e-mail vendite@ivrvalvole.it / sales@ivrvalvole.it

